

LEASING PROPOSAL REQUEST

Agency, Office Name	<u>TDEC - Jackson</u>
Principal Use Office/Warehouse/Other	<u>Office Space + Heated Drive-through Garage/Warehouse space with 3 roll-up doors</u>
Employee Headcount at Premises	<u>54</u>
Transaction Number	<u>18-01-900</u>

	<u>Desired</u>	<u>Alternates Accepted</u>
Service Area and Boundary Requirements	Madison County TN preferably within city of Jackson	
Parking Requirements	<p>132 Total: Paved, lighted, and striped parking for a minimum of 110 Visitor vehicles.</p> <p>In addition to the regular visitor parking needs for this location, the agency will need 22 parking spaces enclosed in a gated fenced area for State vehicles. Fence will need to be a minimum of 8' tall topped with razor or barb wire (fence and gate will be an agency expense invoiced outside of rental rate).</p> <p>The parking provided shall include handicap parking to meet the relevant code requirements.</p>	No
Usable & Rentable Contiguous Square Footage	<p><u>Usable:</u> 14,000-15,400 USF Office 1,000 - 1,200 USF Heated Warehouse/Drive-through Garage space</p> <p><u>Rentable:</u> 15,400 – 16,800 RSF (Office) 1,000-1,200 RSF Heated Warehouse/Drive-through garage space</p> <p>The State expects to pay two lease rates: one lease rate for Office space and another rate for Warehouse space. Proposals with square footages having a 10% deviation (up or down) will not be considered an alternate. The State intends “contiguous” to mean space that is adjacent and single-story. The actual square footage will be determined by programming and space planning.</p>	No
Special Buildout and Other Specifications	Preference is for a single tenant one-story space. See Schedule 1 attached.	Yes

Term Length	Five (5) Years and with a Two (2) Year Option for Renewal	No
Commencement Date	Desired Occupancy by October 1 2019	Yes
Termination Options	Standard Termination for Cause State lease language Termination for Convenience: 90 day cancellation upon written notice	Yes
Terms and Conditions	As set forth in Pro Forma Lease. A copy of the Pro Forma lease form can be found by visiting www.tnpr.gov	
Utility, Services and Other Costs	Preference is for Full Service	Yes

Communications:

Interested parties must direct all communications regarding this procurement to the State Leasing RFP Coordinator, Brannon Butler, who is the State's official point of contact. Email is the preferred form of communication.

Name: Brannon Butler
Phone Number: 615-354-3448
Email: Brannon.butler@tn.gov

Submittal Deadline and Format:

The completed "Lease Proposal Form" (Section II) must be submitted as follows no later than 2pm CDT on September 14, 2018:

Submittals must be received via either:
Email: rfp.coordinator@tn.gov

Or

Printed copy to:
Department of General Services/STREAM
Attn: Brannon Butler
William R. Snodgrass Tennessee Tower 24th Floor
312 Rosa L. Parks Avenue, Nashville, TN 37243
Phone: (615) 354-3448

Method of Evaluation:

Please refer to the State of Tennessee Real Estate Asset Management Division website for the complete document, which describes the proposal evaluation method, by using the following link: www.tnpr.gov.

Disclaimer of Subjectivity:

Proposers should understand and accept that by responding to this solicitation they are willingly participating in a process that may consist of some degree of subjectivity. Proposers should be aware that the proposal determined to best meet the needs of the State may not necessarily be the lowest cost proposal.

Protest Process:

Any protests or appeals of protest pursuant to this Proposal Request or the Notice of Intent to Award shall be handled in accordance with the SBC By laws, Policy and Procedure Item 18.

SCHEDULE 1

Special Build Out Specifications:

Exterior window coverings at Lessors expense, metal blinds

Paved, lighted, and striped parking for a minimum of 110 visitor and staff vehicles.

In addition to the regular parking needs for this location the agency will need 22 lighted, paved, striped parking spaces enclosed in a gated fenced area for State vehicles. Fence will need to be a minimum of 8' tall topped with razor or barb wire (fence and gate will be agency expense).

The parking provided shall include handicap parking to meet the relevant code requirements.

12/20/2017

Space Needs Analysis Report

OFFICE

SNA Number: 32701-57-01

Agency: TDEC, Madison County

Description: Jackson, TN

Prepared by: FMG

Checked by:

Personnel Total: 54 SNA Date: 12/20/201

Type	Standard	Description	Wall	Area	Count
P	02332	Clerk 3	O	51	1
		Administration.			
P	02942	Secretary	O	51	3
		Administration.			
P	02943	Administrative Secretary	O	51	1
		Administration.			
P	07290	PARTAS-REC	O	51	1
		In office 0% to 24% of time. Will share cubicle.			
P	07290	Reg. Dir. of External Aff	H	120	1
		OEA Office of External Affairs.			
P	72924	EC2	O	51	1
		OSP.			
P	73011	EM2	H	120	3
		Water Resources.			
P	73012	EM3	H	120	1
		Air Pollution Control.			
P	73012	EM3	O	51	1
		Remediation. In office 40% of time.			
P	73012	EM3	H	120	1
		Water Resources.			
P	73012	EM3	H	120	1
		Solid/Hazardous Waste Management.			
P	73012	EM3	H	120	1
		Underground Storage Tanks.			
P	73016	EPS2	O	51	3
		Water Resources.			
P	73017	EPS3	O	51	1
		Water Resources.			

Space Needs Analysis Report v1.0 (Archibus)

12/20/2017

Page: 1

With base and wall cabinets, countertop with sink.

S E	Enclave	H	120	3
S ESR	Equipment Storage Room	HA	800	1

Refer to agency memo dated 10/5/15 for additional information. Existing Size.

S GISC	GIS Computer	O	51	1
--------	--------------	---	----	---

GIS computer work station used by Water Resources.

S LCR	Large Conference Room	H	675	1
-------	-----------------------	---	-----	---

Minimum seating for 30. Also used for public hearings.

S LFR	Large File Room	HA	900	1
-------	-----------------	----	-----	---

Includes space for 34 - Single Faced Open Shelving Units and 18 - Double Faced Open Shelving Units.

S MA	Mail Area	O	64	1
S PRA	Plans Review Area	O	120	2

Used by Water Resources.

S RL	Reference Library	H	200	1
S SCR	Small Conference Room	H	260	2

Each room to accommodate seating for 12 around tables.

S SR	Supply Room	H	250	1
------	-------------	---	-----	---

Also supports field office staff and 10 County offices.

S SRC	Shared Rec. Cubical	O	51	1
-------	---------------------	---	----	---

Shared Reception Cubical. Secretaries will share the use of this cubical when serving public in the waiting room. Includes space for telephone system console, desktop computer, printer, scanner, locking cash drawer and shelving for reference manuals.

S TC	Telecom. Closet	H	100	1
------	-----------------	---	-----	---

For telephone and computer equipment. Room must be temperature controlled.

S WA	Work Area	O	250	1
------	-----------	---	-----	---

Includes space for Multi-Function copy machines, GIS Computer, Printers, Plotter and Maps used by Remediation

S WL	Wet Laboratory	H	525	1
------	----------------	---	-----	---

Existing size. This room has specific requirements to meet the need of the agency including a dressing area with shower and lockers. Refer to agency memo dated 10/5/15 for additional information.

S WR	Waiting Room	HA	500	1
------	--------------	----	-----	---

With transaction countertop and locking sliding pass-thru window to shared reception cubical. Includes space for file review area and a minimum of 13 chairs. Room must have direct access client restrooms. Client and staff restrooms will be separate and will not share the same plumbing wall.

Comments:

Environment Assistance Center. In addition to the regular parking needs for this location the agency will need 22 parking spaces enclosed in a gated fenced area for State vehicles. Fence will need to be a minimum of 8' tall topped with razor or barbed wire (fence and gate will be agency expense). Must add the total minimum usable sq. ft. from this SNA with SNA# 32701-57-02 which includes both acreage. DO NOT RUN MULTIPLE REPORT. Both SNAs will total 14,917 minimum usable sq. ft. Refer to agencies memorandum dated 10/5/15 for agency specific requirements. All agency requirements that are not typical FRF office space requirements will be an agency expense.

Major Circulation: 30%
Total Area Needed: 10,705
GRAND TOTAL: 13,917

Suggested Range (office)	Min.	Max.
Usable:	14,000	15,400
Rentable:	15,400	16,800

12/20/2017

Space Needs Analysis Report

SNA Number: 32701-57-02 Garage

Agency: TDEC, Madison County

Description: Jackson, TN

Prepared by: FMG

Checked by:

Personnel Total: 0 SNA Date: 12/20/201

Type	Standard	Description	Wall	Area	Count	Access	Paint	Needed
S	BEG	Boat/Equipment Garage	H	1,000	1	0	0	1,000

Used for boat, ATV and field equipment storage. Heat required but not A.C. Refer to agency memo dated 10/5/15 for other requirements.

Totals: 1 0 0 1,000

Comments:

This SNA includes space needed, (by the Madison Co. Environmental Assistance Center) to store boats and related equipment. DO NOT RUN MULTIPLE REPORT. This SNA report must be printed by it self and then the total minimum usable sq. ft. added to SNA# 32701-57-01. The total minimum usable sq. ft. of both SNAs is 14,917 usable sq. ft.
SNA Number: 32701-57-02

Major Circulation: 0%
Total Area Needed: 1,000
GRAND TOTAL: 1,000

Suggested Range: Min. Max.
Usable: 1,000 1,200
Rentable: 1,000 1,200

GENERAL SPECIFICATIONS**1. General**

- a. The Leased Premises, including all common areas and points of ingress and egress, shall be designed and maintained to meet all applicable code requirements for commercial office building construction, including the requirements of the Americans with Disabilities Act.
- b. The Leased Premises shall have a current occupancy permit issued by the local jurisdiction at the time of Tenant's occupancy.

2. Site

- a. The site shall be fully graded, landscaped and maintained in a manner commensurate with market for comparable properties of the same property type and class as the Leased Premises.

3. Structure

- a. Space above ceilings must allow sufficient clearance for ease of installation of Tenant's mechanical and electrical equipment, including but not limited to distribution ductwork, HVAC boxes, lighting and conduit.
- b. The building foundation and below-grade spaces shall be protected with a properly installed foundation drainage and waterproofing system.

4. Building Skin and Roof

- a. The building skin and roof will be complete and weather-tight including all exterior finish materials, cladding, sealants, glass and glazing including vision and spandrel glass, store front glass, exterior doors and hardware, membrane or built-up roofing, ballast, flashing, and other elements required to make the building weather-tight.

5. Building Common Areas

- a. The building entrance lobby, common corridors, restrooms, mechanical spaces, loading dock, trash removal spaces, and other common areas will be substantially complete.
- b. Restrooms shall be complete with all fixtures, partitions, accessories, lavatories, lavatory tops, and mirrors. Fixtures, partitions, and accessories shall be institution grade or better, and shall be water saving type, as appropriate. The finishes in restrooms shall be commensurate with market for comparable properties of the same property type and class as the Leased Premises.

6. Common Walls

- a. Common walls shall include slab-to-slab gypsum wallboard on the public side of all demising walls, corridors, stairwells, and other walls not interior to the Tenant space. All common walls shall be taped, blocked, finished and sanded. Landlord will install sound attenuation insulation on Tenant side of Common Walls and demising walls prior to Tenant finishes being installed.
- b. Common walls shall include entry and exit doors from common areas furnished and installed by Landlord. Doors and hardware shall be building standard or better.

7. Electrical

- a. Landlord shall provide a minimum of 7 watts per square foot for lighting and power.
- b. Landlord shall install all main switchboards, panel boards, distribution boards, transformer, bus duct, feeders and other equipment to completely distribute power to electrical closets on each floor in the Leased Premises. Landlord shall locate an electrical service panel in the electrical closet in the Common Area on the same floor as the Leased Premises. Installation of electrical service up to and including the Tenant's service panel(s) shall be a base building cost.
- c. Landlord shall install all wiring, branch circuiting, conduit and devices for the complete electrical system to all public and common areas. Landlord shall provide at Landlord's expense all power wiring and connection for all mechanical equipment furnished as part of base building. Landlord shall provide at Landlord's expense all power wiring to life safety and fire protection systems.

8. Communications

- a. Landlord shall bring data/telephone service, as provided by the local data/telephone operating company, to the building Main Telephone Room.

9. Lighting

- a. Landlord shall furnish and install lights in all common areas.

- b. Building lighting levels must meet a minimum of 30 foot-candles at the desk and 20 foot-candles in corridors providing ingress and egress to the Leased Premises. Base building shall include a lighting level of at least 10 foot-candles or minimum levels to insure safety in other interior areas as set by the current version of the Illuminating Engineering Society of North America (IESNA).

10. Plumbing

- a. Plumbing tie-ins shall be provided for State's use for break room or other functions required by the Permitted Use.

11. HVAC

- a. Building common areas shall include heating, ventilation, and air conditioning systems in accordance compliance with current ASHRAE standards.
- b. All HVAC for the Leased Premises shall be installed with complete distribution to ceiling mounted diffusers and perimeter slot diffusers for exterior zones and distribution to VAV boxes for interior zones.

12. Building Directory

- a. If the Building has multiple tenants, Landlord shall provide a directory in the lobby of the Building.
- b. Landlord shall add Tenant's name to directory, and shall provide Tenant suite signage (suite entry door plaque or hall plaque, matching building graphics standards).

13. Keys

- a. Landlord shall supply Tenant with five (5) sets of keys at no cost. Additional keys shall be provided at Tenant's request at a reasonable cost. Keys should allow access to the Leased Premises, parking areas and other common areas of the Property.

14. Access Control

- a. Landlord shall provide new locks on all exterior doors and doors into common areas.
- b. Tenant may install card access to the Leased Premises at suite entry locations, fire stairs with access into the Leased Premises and interior doors within the Leased Premises compatible with the base building security system.
- c. Provide heavy-duty cylindrical hardware within suite and heavy duty mortised lockset at suite entry doors.
- d. Provide locksets on the following doors: offices, enclaves, communication rooms, utility rooms, storage/file rooms, network rooms.

INTERIOR BUILDOUT SPECIFICATIONS

1. Ceiling

- a. Existing ceiling tile and grid shall remain if these materials meet the Minimum Qualification Specification (Section e below) and are in good and attractive condition. Patch and repair grid as needed to accommodate demolition of walls. Replace any damaged or discolored tiles to match existing.
- b. Existing lighting shall be cleaned and re-lamped after construction. All lamps shall be the same color temperature. Coordinate the appropriate lamp color with the State.
- c. Provide 15'-20' whip at all above-ceiling junction boxes for power pole connections.
- d. Minimum ceiling heights shall be a minimum of 8 feet and be proportionate to the open area floor plate size.
- e. Acoustical Panel Ceiling Minimum Qualification Specifications:
- f. General Ceiling
 - i. Acoustical Panel Standard: Comply with ASTM E 1264.
 - ii. Metal Suspension System Standard: Comply with ASTM C 635.
 - iii. Attachment Devices: Size for five times the design load indicated in ASTM C 635, Table 1, "Direct Hung," Comply with seismic design requirements.
- g. Acoustical Panels
 - i. Color: White.
 - ii. LR: Minimum of 0.83.
 - iii. NRC: Minimum of 0.60, Type E-400 mounting according to ASTM E 795.
 - iv. CAC: Minimum of 33.
 - v. Modular Size: 24 by 24 inches (610 by 610 mm) or 24 by 48 inches (610 by 1220 mm).

2. Electrical and Communication

- a. Provide and install conduit, conductors, pull wires, boxes, cover plates, devices, etc., for all outlets as required by the Build Out Plans. All devices shall be a consistent color.
- b. Contractor shall be responsible for all coordination and final electrical connections for furniture (systems furniture, conference/training tables, etc.). Coordinate with State for specifics on wiring configurations. For general planning purposes, provide 1 circuit per every 2 standard workstations as required by the Build Out Plans.
- c. Provide 1 voice/data per standard workstation as required by the Build Out Plans.
- d. Provide 2 duplex power outlets and 1 voice/data per standard office as required by the Build Out Plans.
- e. Provide 2 duplex power outlets and 1 voice/data per enclave as required by the Build Out Plans.
- f. At minimum, all enclosed rooms (such as storage and file rooms) to have (2) convenience duplex power outlets as required by the Build Out Plans.
- g. Lighting and controls shall be properly zoned. Separate light switches for hardwall spaces shall be provided as required by the Build Out Plans.

3. Partitions

- a. All existing perimeter sill walls and core walls throughout space shall be freshly painted in an eggshell or satin paint finish.
- b. All new partitions to be 5/8" drywall and 3 5/8" metal studs with sound attenuation blankets inside the partition. Additional sound blankets to be provided above partitions on ceiling tile, 2'-0" on either side of all new or existing partitions not extending to the deck.
- c. Partitions around all new conference rooms, training rooms, break rooms, meeting rooms, and restrooms, shall extend to the deck. Sound attenuation blankets shall be provided inside the partition, seal all penetrations within partitions including power/data boxes and at the connection of the partition to the deck.
- d. Connections from partition to mullion will require an acoustically sealed connection.
- e. Finish partitions completely to floor.

4. Glazing

- a. All office, enclave, break room, and conference room front walls shall have a 3'-0" wide sidelite with ¼" clear tempered glass in 2" welded hollow metal frame with a solid core door (match building standard), and etched film on 3'-0" w full height sidelights. Framing for glass sidelights and windows shall be integral with doorframes and not separated by drywall.

5. Doors and Frames

- a. Interior doors shall match building standard height and finish; at a minimum, all doors shall be solid core, 7'-0" in height.
- b. Interior doorframes shall be 2" welded hollow metal steel, painted.
- c. All hardware shall match existing building standard finish. At a minimum, all hardware shall be lever handle. All doors shall include the following: doorstops, silencers, lever hardware, mortised ball bearing hinges. All office doors shall include a coat hook. In addition, pairs of doors shall include the following as determined by function: dummy trim, closer coordinators, flush bolts, dust proof strikes, ball catch (as required).
- d. All main entrance public access doors shall be metal frame glass storefront entrance type with double-pane glass. Exterior exit doors shall be metal framed with insulated flush type metal door. All exterior doors must be equipped with commercial grade closers and hardware.

6. Finishes

- a. Doors, frames, hardware, ceiling tile and grid and lights shall be reused if approved by the State.
- b. Carpet shall be modular tiles laid with low VOC adhesives. Carpet shall generally be laid in a monolithic, ashlar or brick laid pattern. Carpet shall not be laid in a quarter turn pattern unless noted specifically.
- c. Carpet must meet the following minimum qualification specifications:
 - i. Products: All manufacturers to provide modular tile products as specified below and in addition to meeting the minimum requirements.
 - ii. Commercial Face Fibers: High performance premium branded Nylon required to be third party certified post-consumer recyclable and defined as a commercial grade nylon fiber from a carpet or fiber manufacturer nationally recognized by the flooring industry; the nylon fiber shall have a documented five (5) year minimum successful testing period; Note: OLEFIN FIBER IS NOT ACCEPTABLE.
 - iii. Pile Characteristic: Level-loop, Cut-and-loop pile, Shear-and-loop pile.
 - iv. Density: Minimum rating of 5,000 or higher.
 - v. Stitches: Minimum of 9 stitches per inch.
 - vi. Gage: 1/12 inch minimum.
 - vii. Surface Pile Weight: Minimum 20 oz. per square yard.
 - viii. Dye System: Minimum of 50% solution dyed or yarn dyed (Type 6, Type 6,6 or proven equal).
 - ix. Backing System: Provide applicable backing system based on carpet type/brand selected.
 - x. Size: 24 by 24 inches (610 by 610 mm) or larger.
 - xi. Applied Soil-Resistance Treatment: Duratech, Protech, or equal (specify with proposal).
 - xii. Antimicrobial Treatment: Manufacturer's standard material according to AATCC174.
- d. Provide 4" coved rubber base in areas specified to receive new flooring. All base shall be continuous roll base (not 4' segments).
- e. All walls to have one prime coat and 2 finish coats of eggshell or satin finish. Door and window frames shall have semi-gloss finish. Drywall ceilings shall have flat finish.
- f. Where identified as laminate finish on casework, use color core laminates for exposed surfaces for doors, drawers, counter tops and splashes. The underside of all vertical laminate panels in wet areas shall receive a laminate or pvc edge to prevent water from wicking up through laminate panel substrates. Counters and splashes shall be thoroughly caulked to walls and countertops using clear silicone caulk.

7. Break Rooms

- a. Finishes: VCT floor tile in a floor pattern using 3 different colors, plastic laminate base and wall cabinets.
- b. Provide double bowl, under mount stainless steel sink with hot/cold water.
- c. Provide dedicated outlets for refrigerators, microwaves, and (2) coffee makers. Provide (3) standard wall duplex outlets at 42" AFF in kitchen area. Provide (2) additional wall outlets at other walls for convenience purposes.

8. Copy Rooms / Areas

- a. Finishes: VCT flooring, plastic laminate base and wall cabinets, plastic laminate countertop. Cabinetry shall be sufficient to meet the needs of the Tenant at its sole discretion.
- b. Provide (2) wall duplex outlets (one circuit) and (2) voice/data outlets at 42" AFF in work area.

9. Telecom Rooms

- a. Finishes: VCT flooring, 4" rubber base.
- b. Walls shall extend to deck; no lay-in ceiling.
- c. A minimum of a half-ton (5,000 BTU's) of cooling for coverage of equipment is required. Stand-alone mechanical unit is preferred. If stand-alone is not possible, then the space should be removed from the EMS and have VAV-type controls.
- d. Provide at least a 3" conduit from the interior telecom room or non-common space to an exterior right of way or utility easement for new service provider connection. Coordinate with service provider.
- e. Each telecom room should be a minimum of 8' x 10' in size, with one room per 15,000 square feet of usable space. Telecom rooms shall align vertically if in a multiple-floor facility.
- f. Doors to telecom rooms shall open out into the corridor, if possible. If this is not possible, then locate the door in an area with minimal clearance impact.
- g. Provide at least (2) dedicated quad outlets, 110 volt, 20 amp circuits, in addition to the normal service outlets.
- h. The State cabling contractor, at State's expense, shall install a grounding bus bar and place correctly-sized conductor back to the main panel for facility personnel to connect.
- i. Telecom rooms do not include space for building/energy automation/management, life safety controls, or security, audio, or CC/CATV systems.

10. Conference Rooms

- a. All conference rooms that seat (8) people or more shall have (2) power and voice/data outlets. Larger Conference rooms of greater than (18) people shall have (4) power and (2) voice/data outlets.
- b. Lighting switching shall provide flexibility for a variety of scene configurations for different presentations and meetings. Fixtures shall provide both ambient lighting to the table as well as accent wall wash lighting at the perimeter of the room.
- c. Coordinate placement of switches, AV screens, furniture, & doors so as to avoid conflicts when components are in use.

11. Restrooms

- a. All restrooms shall be equipped with liquid soap dispensers and mirrors, and either paper towel dispensers or hand blow dryers.
- b. Provide a floor drain in each restroom.

12. Janitor Closet

- a. Finishes: VCT flooring, 4" rubber base.
- b. Provide storage for equipment, materials, and supplies, in a minimum 25 sf room.
- c. Provide service sink with hot and cold water and a floor drain.

13. Building Interior

- a. Provide (accessible) chilled drinking fountains as per code requirements. If it is deemed necessary to replace existing or incorporate additional drinking fountains, equipment shall be able to accommodate a water bottle refill component.
- b. Provide evacuation maps and other interior signage as required and requested by the State. Coordinate locations with the State.

14. Building Exterior

- a. Provide exterior canopies at all building entrances and exits, as well as a vestibule/airlock at all public entrances.
- b. Provide exterior signage and dumpster access.
- c. Hard-surface exterior walkways shall be provided to connect all Building entrances and exits to on-site parking lots or other hard-surfaced areas